

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

Project Information

Valentin Residence
 4350 E. Mercer Way Parcel No.004610-0151
 Mercer Island, WA 980940

Contact Information

Johan Valentin
 PO Box 52641
 Bellevue, WA 98015

Heating System Type:

- All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

Design Temperature

Instructions

Mercer Island

Design Temperature Difference (T)
 T = Indoor (70 degrees) - Outdoor Design Temp

45

Area of Building

Conditioned Floor Area

Instructions

Conditioned Floor Area (sq ft)

6,395

Average Ceiling Height

Instructions

Average Ceiling Height (ft)

9.0

Conditioned Volume
 57,555

Glazing and Doors

Instructions

U-0.30

U-Factor X Area = UA
 0.300 X 1,499 = 449.64

Skylights

Instructions

U-Factor X Area = UA
 0.50 X 64 = 32.00

Insulation

Attic

Instructions

R 49

U-Factor X Area = UA
 0.026 X 2,897 = 75.32

Single Rafter or Joist Vaulted Ceilings

Instructions

No Vaulted Ceilings in this project.

U-Factor X Area = UA

Above Grade Walls (see Figure 1)

Instructions

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 4,265 = 238.84

Floors

Instructions

R 30

U-Factor X Area = UA
 0.029 X 923 = 26.77

Below Grade Walls (see Figure 1)

Instructions

R-21 Interior

U-Factor X Area = UA
 0.042 X 751 = 31.53

Slab Below Grade (see Figure 1)

Instructions

R 10 Fully insulated

F-Factor X Length = UA
 0.303 X 2,552 = 773.26

Slab on Grade (see Figure 1)

Instructions

R 10 Fully Insulated

F-Factor X Length = UA
 0.360 X 0 = 0

Location of Ducts

Instructions

Conditioned Space

Duct Leakage Coefficient
 1.00

Sum of UA	1627.35
Envelope Heat Load	73,231 Btu / Hour
<i>Sum of UA X T</i>	
Air Leakage Heat Load	27,972 Btu / Hour
<i>Volume X 0.6 X T X .018</i>	
Building Design Heat Load	101,203 Btu / Hour
<i>Air Leakage + Envelope Heat Loss</i>	
Building and Duct Heat Load	101,203 Btu / Hour
<i>Ducts in unconditioned space: Sum of Building Heat Loss X 1.10</i>	
<i>Ducts in conditioned space: Sum of Building Heat Loss X 1</i>	
Maximum Heat Equipment Output	141,684 Btu / Hour
<i>Building and Duct Heat Loss X 1.40 for Forced Air Furnace</i>	
<i>Building and Duct Heat Loss X 1.25 for Heat Pump</i>	

Figure 1.

