

November 5, 2019

City of Mercer Island **Development Services Group** 9611 SE 36th Street Mercer Island, WA 98040

RE: 7450 N Mercer Way

Mercer Island, WA 98040

Permit # 1904-048

We have updated the plans to match the revised architecture and performed an in-house review. The structural plans have been revised as outlined below.

Sheet S1.1

Additional reinforcing added for 10" and 12" walls.

Sheet S2.1

- Wall openings and shifted on west elevation.
- Additional site walls shown on structural plans.
- New storage shown under east deck, structural drawings revised.
- Concrete stair added to east side of property.

Sheet S2.2

- Deck framing joist spacing reduced to 12" on center.
- Connection from wide flange to concrete walls revised
- Storage room revisions same as S2.1.

Sheet S2.3

- Drawings clarify for ledger and lateral attachment.
- Single post in place of previous double post.

Sheet S3.1

- Detail 6 revised for larger footing.
- Detail 9 removed.

Sheet S3.2

- Detail 8 added.
- Clarifications on details 3 and 4.
- (2) #4 bars at top of wall specified on detail 12

Sheet S4.2

- Details 2 and 6 removed.
- Detail 8 revised to show attachment from steel beam to porch roof framing.

Swenson Say Fagét

STRUCTURAL ENGINEERING

2124 Third Ave, Suite 100 Seattle, WA 98121 **o** 206.443.6212

934 Broadway, Suite 100 Tacoma, WA 98402 o 253.284.9470



ssfengineers.com

- Detail 12 revised to show single post.
- Detail 11 added to show clarification for beam to concrete wall attachment.
- Detail 9 added to show attachment from concrete wall to parallel deck framing.

We have clouded the revisions and included revised calculations.

We trust this addresses all the structural concerns. Please give us a call if you have any further questions. Thank you.

Sincerely,

SWENSON SAY FAGÉT

A Structural Engineering Corporation

Karl Rosman PE
Associate Principal

