

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

Project Information

Marshall Residence
 4307 E. Mercer Way
 Mercer Island, WA 98040

Contact Information

Brad Sturman-Sturman Architects
 9 103rd Ave NE Ste. 203
 Bellevue, WA 98004

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

Design Temperature

[Instructions](#) Mercer Island

Design Temperature Difference (ΔT) 45
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#) Conditioned Floor Area (sq ft) 2,742

Average Ceiling Height

[Instructions](#) Average Ceiling Height (ft) 8.0

Conditioned Volume 21,932

Glazing and Doors

[Instructions](#) U-0.30

U-Factor X Area = UA
 0.300 461 138.30

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 14 6.85

Insulation

Attic

[Instructions](#) R-49

U-Factor X Area = UA
 0.026 1,952 50.75

Single Rafter or Joist Vaulted Ceilings

[Instructions](#) No Vaulted Ceilings in this project.

U-Factor X Area = UA
 --- --- ---

Above Grade Walls (see Figure 1)

[Instructions](#) R-21 Intermediate

U-Factor X Area = UA
 0.056 2,176 121.86

Floors

[Instructions](#) R-30

U-Factor X Area = UA
 0.029 1,031 29.90

Below Grade Walls (see Figure 1)

[Instructions](#) R-21 Interior

U-Factor X Area = UA
 0.042 656 27.55

Slab Below Grade (see Figure 1)

[Instructions](#) R-5 Thermal Break at slab edge

F-Factor X Length = UA
 0.570 719 409.83

Slab on Grade (see Figure 1)

[Instructions](#) No Slab on Grade in this project.


F-Factor X Length = UA
 --- --- ---

Location of Ducts

[Instructions](#) Conditioned Space

Duct Leakage Coefficient
 1.00

Figure 1.



Sum of UA	785.04
Envelope Heat Load	35,327 Btu / Hour
<i>Sum of UA X ΔT</i>	
Air Leakage Heat Load	10,659 Btu / Hour
<i>Volume X 0.6 X ΔT X .018</i>	
Building Design Heat Load	45,986 Btu / Hour
<i>Air Leakage + Envelope Heat Loss</i>	
Building and Duct Heat Load	45,986 Btu / Hour
<i>Ducts in unconditioned space: Sum of Building Heat Loss X 1.10</i>	
<i>Ducts in conditioned space: Sum of Building Heat Loss X 1</i>	
Maximum Heat Equipment Output	57,482 Btu / Hour
<i>Building and Duct Heat Loss X 1.40 for Forced Air Furnace</i>	
<i>Building and Duct Heat Loss X 1.25 for Heat Pump</i>	