

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

The glazing (window) and door portion of this calculator assumes the installed glazing and door products have an area weighted average U-factor of 0.30. The incorporated insulation requirements are the minimum prescriptive amounts specified by the 2015 WSEC.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

Project Information

YUAN RESIDENCE
3611 WEST MERCER WAY
MERCER ISLAND, WA 98040

Contact Information

BRANDT DESIGN GROUP
LISA LINDBURG
lisa@brandtdesigninc.com

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference (ΔT)
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

45

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

3,929

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

11.8

Conditioned Volume

46,166

Glazing and Doors

[Instructions](#)

U-Factor X Area = UA
0.30 X 1,657 = 496.95

U-Factor X Area = UA
0.50 X 21 = 10.50

Skylights

[Instructions](#)

U-Factor X Area = UA
No selection X = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
0.027 X 2,102 = 56.75

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
0.056 X 3,313 = 185.51

Floors

[Instructions](#)

No Floors above unconditioned spaces.

U-Factor X Area = UA
--- X = ---

Below Grade Walls (see Figure 1)

[Instructions](#)

R-10 Continuous Exterior

U-Factor X Area = UA
0.064 X 862 = 55.17

Slab Below Grade (see Figure 1)

[Instructions](#)

R-5 Thermal Break at slab edge

F-Factor X Length = UA
0.570 X 114 = 64.70

Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor X Length = UA
0.360 X 190 = 68.22

Location of Ducts

[Instructions](#)

No Ducts

Duct Leakage Coefficient
1.00

Sum of UA 937.80
Envelope Heat Load 42,201 Btu / Hour
Sum of UA X ΔT
Air Leakage Heat Load 22,437 Btu / Hour
Volume X 0.6 X ΔT X .018
Building Design Heat Load 64,638 Btu / Hour
Air Leakage + Envelope Heat Loss
Building and Duct Heat Load 64,638 Btu / Hour
Ducts in unconditioned space: Sum of Building Heat Loss X 1.10
Ducts in conditioned space: Sum of Building Heat Loss X 1
Maximum Heat Equipment Output 90,493 Btu / Hour
Building and Duct Heat Loss X 1.40 for Forced Air Furnace
Building and Duct Heat Loss X 1.25 for Heat Pump

Figure 1.

