

Lisa Lindburg
Brandt Design Group
66 Bell Street
Seattle, WA 98121
lisa@brandtdesigninc.com
July 19, 2019

Re: 1907-017

Nicole Gaudette and Paul Skidmore
Community Planning & Development
City of Mercer Island

The Yuan permit set has been revised and we are responding to your intake submittal comments. Below are the itemized changes that are clouded on each sheet as revision 1.

ARCHITECTURAL:

Sheet #	TITLE	REVISION
Sheet A000	Coversheet	1. Revised Lot coverage calculation. The 192 SF deck canopy was mistakenly identified as an “accessory building” and is now included in the overall building SF.
Sheet A100	Site Plan	1. Utilities and utility easements are now shown. These include the sewer easement, overhead power and water. 2. Revised Lot coverage calculation. The 192 SF deck canopy was mistakenly identified as an “accessory building” and is now included in the overall building SF.
Sheet D100	Demo Site Plan	1. Revised Lot coverage calculation. The 192 SF deck canopy was mistakenly identified as an “accessory building” and is now included in the overall building SF.
Sheet 300	Exterior Elevations	Site cut and fill outside of the building footprint is shown.
Sheet 301	Exterior Elevations	Site cut and fill outside of the building footprint is shown.

STRUCTURAL:

Structural drawings bookmarks have been synchronized with the appropriate sheet.