

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

Project Information

Baze-Inoguchi Residence
 2723 72nd Ave SE
 Mercer Island, WA 98040

Contact Information

Matt Mawer
 425.417.7817

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference (ΔT) 45
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

3,340

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.0

Conditioned Volume

30,060

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 654 = 183.12

U-Factor X Area = UA
 0.50 X 0 = ---

Skylights

[Instructions](#)

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA
 0.027 X 1,443 = 38.96

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,375 = 133.00

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
 0.025 X 765 = 19.13

Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA
 0.042 X 873 = 36.67

Slab Below Grade (see Figure 1)

[Instructions](#)

R-10 Fully insulated

F-Factor X Length = UA
 0.303 X 101 = 30.60

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
 --- X 0 = ---


Location of Ducts

[Instructions](#)

Conditioned Space

Duct Leakage Coefficient
 1.00

Figure 1.



| | |
|---|-------------------|
| Sum of UA | 441.48 |
| Envelope Heat Load | 19,866 Btu / Hour |
| <i>Sum of UA X ΔT</i> | |
| Air Leakage Heat Load | 14,609 Btu / Hour |
| <i>Volume X 0.6 X ΔT X .018</i> | |
| Building Design Heat Load | 34,476 Btu / Hour |
| <i>Air Leakage + Envelope Heat Loss</i> | |
| Building and Duct Heat Load | 34,476 Btu / Hour |
| <i>Ducts in unconditioned space: Sum of Building Heat Loss X 1.10</i> | |
| <i>Ducts in conditioned space: Sum of Building Heat Loss X 1</i> | |
| Maximum Heat Equipment Output | 43,094 Btu / Hour |
| <i>Building and Duct Heat Loss X 1.40 for Forced Air Furnace</i> | |
| <i>Building and Duct Heat Loss X 1.25 for Heat Pump</i> | |