

# Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

### Project Information

Forest Ave Residence  
 5202 Forest Ave SE  
 Mercer Island, WA 98040

### Contact Information

Brad Sturman - Sturman Architects  
 9- 103rd Ave NE Ste. 203  
 Bellevue, WA 98004

**Heating System Type:**  All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

### Design Temperature

[Instructions](#) Mercer Island

Design Temperature Difference ( $\Delta T$ ) 45  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

### Area of Building

#### Conditioned Floor Area

[Instructions](#) Conditioned Floor Area (sq ft) 5,051

#### Average Ceiling Height

[Instructions](#) Average Ceiling Height (ft) 8.9

Conditioned Volume 45,061

### Glazing and Doors

[Instructions](#) U-0.30

**U-Factor X Area = UA**  
 0.300 X 935 = 280.47

### Skylights

[Instructions](#)

**U-Factor X Area = UA**  
 0.50 X --- = ---

### Insulation

#### Attic

[Instructions](#) Select R-Value

**U-Factor X Area = UA**  
 No selection X --- = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#) R-38 Vented

**U-Factor X Area = UA**  
 0.027 X 2,194 = 59.24

#### Above Grade Walls (see Figure 1)

[Instructions](#) R-21 Intermediate

**U-Factor X Area = UA**  
 0.056 X 4,798 = 268.69

#### Floors

[Instructions](#) R-38

**U-Factor X Area = UA**  
 0.025 X 1,377 = 34.43

#### Below Grade Walls (see Figure 1)

[Instructions](#) R-21 Interior

**U-Factor X Area = UA**  
 0.042 X 326 = 13.69

#### Slab Below Grade (see Figure 1)

[Instructions](#) Select conditioning

**F-Factor X Length = UA**  
 No selection X --- = ---

#### Slab on Grade (see Figure 1)

[Instructions](#) R-10 Perimeter


**F-Factor X Length = UA**  
 0.540 X 220 = 118.80

### Location of Ducts

[Instructions](#) Conditioned Space

Duct Leakage Coefficient 1.00

Figure 1.



<b>Sum of UA</b>	775.31
<b>Envelope Heat Load</b>	34,889 Btu / Hour
<i>Sum of UA X <math>\Delta T</math></i>	
<b>Air Leakage Heat Load</b>	21,899 Btu / Hour
<i>Volume X 0.6 X <math>\Delta T</math> X .018</i>	
<b>Building Design Heat Load</b>	56,789 Btu / Hour
<i>Air Leakage + Envelope Heat Loss</i>	
<b>Building and Duct Heat Load</b>	56,789 Btu / Hour
<i>Ducts in unconditioned space: Sum of Building Heat Loss X 1.10</i>	
<i>Ducts in conditioned space: Sum of Building Heat Loss X 1</i>	
<b>Maximum Heat Equipment Output</b>	70,986 Btu / Hour
<i>Building and Duct Heat Loss X 1.40 for Forced Air Furnace</i>	
<i>Building and Duct Heat Loss X 1.25 for Heat Pump</i>	