

# Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

## Project Information

Forest Ave Residence  
5202 Forest Ave SE  
Mercer Island, WA 98040

## Contact Information

Brad Sturman - Sturman Architects  
9- 103rd Ave NE Ste. 203  
Bellevue, WA 98004

### Heating System Type:

All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

### Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference ( $\Delta T$ ) 45  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

4,889

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.0

Conditioned Volume  
44,001

### Glazing and Doors

[Instructions](#)

U-0.30

U-Factor X Area = UA  
0.300 X 935 = 280.47

### Skylights

[Instructions](#)

U-Factor X Area = UA  
0.50 X --- = ---

### Insulation

#### Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA  
No selection X --- = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA  
0.027 X 2,133 = 57.59

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 4,158 = 232.85

#### Floors

[Instructions](#)

R-38

U-Factor X Area = UA  
0.025 X 895 = 22.38

#### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA  
0.042 X 326 = 13.69

#### Slab Below Grade (see Figure 1)

[Instructions](#)

Select conditioning

F-Factor X Length = UA  
No selection X --- = ---

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Perimeter

F-Factor X Length = UA  
0.540 X 135 = 72.90


### Location of Ducts

[Instructions](#)

Conditioned Space

Duct Leakage Coefficient  
1.00

Figure 1.



|   |                   |
|---|-------------------|
| <b>Sum of UA</b>  | 679.88            |
| <b>Envelope Heat Load</b>   | 30,594 Btu / Hour |
| <i>Sum of UA X <math>\Delta T</math></i>                              |                   |
| <b>Air Leakage Heat Load</b>  | 21,384 Btu / Hour |
| <i>Volume X 0.6 X <math>\Delta T</math> X .018</i>                    |                   |
| <b>Building Design Heat Load</b>                                      | 51,979 Btu / Hour |
| <i>Air Leakage + Envelope Heat Loss</i>                               |                   |
| <b>Building and Duct Heat Load</b>                                    | 51,979 Btu / Hour |
| <i>Ducts in unconditioned space: Sum of Building Heat Loss X 1.10</i> |                   |
| <i>Ducts in conditioned space: Sum of Building Heat Loss X 1</i>      |                   |
| <b>Maximum Heat Equipment Output</b>                                  | 64,974 Btu / Hour |
| <i>Building and Duct Heat Loss X 1.40 for Forced Air Furnace</i>      |                   |
| <i>Building and Duct Heat Loss X 1.25 for Heat Pump</i>               |                   |