

DRAINAGE PUMP DESIGN


FOR

SINGLE FAMILY RESIDENCE

4245 90TH AVE SE

MERCER ISLAND, WA 98040

November 16, 2020



Prepared by

C2MY Engineers, LLC
P.O. Box 52883
Bellevue, WA 98015-2883
Contact: Choomeng Chin
(206) 922-9376
cmchin.c2my@gmail.com

Prepared for

PBG, LLC
5130 S. 166th Lane
SeaTac, WA 98188
Contact: Han Pham, P.E.
(206)-229-6422
pbg.egr@yahoo.com

This page is intentionally left blank

TABLE OF CONTENTS

I. PROJECT OVERVIEW	5
A. Pump Design Requirements:.....	5
II. PUMP DESIGN DESIGN	7
A. Summary of Input Data:.....	7
B. Developed Peak flow Calculation:.....	9
C. Storm Duplex Pump design:	11
D. Pump Curve:	13

This page is intentionally left blank

I. PROJECT OVERVIEW

This report provides the drainage pump system design calculation for the redevelopment of a single-family residence building. The detention system is too deep for gravity discharge to the roadway drainage system and hence a pump is needed. The pump system is designed to discharge the maximum allowable flow rate from the detention system including the 100-year storm frequency.

A. Pump Design Requirements:

Per city requirements:

- a. The pump system shall have dual, alternating pumps with emergency on-site, back-up power supply and an external alarm system for system failure and high water level indicator.
- b. Provide a detail section for the pump system and the structure with all dimensions and invert elevations shown.
- c. Pumped flows shall not exceed the allowable discharge rates set forth herein. Each pump shall be capable of discharging the design flow rate for the 100-year, 24-hour design storm. Provide detail calculations for the pump system including pump curve.
- d. If a stormwater detention system is not required the pump system shall have a storage facility (pond, tank, or vault) sized to hold 25 percent of the total volume of runoff for the developed tributary drainage area for the 2-year, 24-hour design storm.
- e. The pump system shall discharge to an elevation higher than the downstream design water surface elevation to prevent backwater/backflow conditions. Provide such design.




FIGURE 1: PROPOSED SITE DEVELOPEMENT MAP (NTS)

II. PUMP DESIGN DESIGN

The calculated peak runoffs using the SBUH methodology are as follow:

Drainage area= 1728 S.F. (0.0397 acs)

The allowable discharge per the detention standards are as follow:

- 2-yr/24hr – 0.0058 cfs (5 gpm) (50% of existing condition flow rate)
- 10-yr/24hr – 0.0205 cfs (11 gpm) (Existing condition flow rate)
- 25-yr/24hr – 0.0251 cfs (13 gpm) (Existing condition flow rate)
- 100-yr/24hr – 0.0298 cfs (15 gpm) (Existing condition flow rate)

Minimum Pump Design working depth = 1.73 feet (

The 4-ft diameter pump well with 3’ sump provide 281.99 gallon of volume > 162.68 gallon. O.k.

A. SUMMARY OF INPUT DATA:

Drainage area = 1005 SF

TIME OF CONCENTRATION CALCULATIONS

24 hr. ISOPLUVIALS:

P2=	2.00	in/day
P10=	3.00	in/day
P100=	4.00	in/day

sheet flow:	$Tt = \{(.42)(Ns*L)^{0.8}\} / \{(P2)^{0.5} * (So)^{0.4}\}$
conc. flow:	$Tt = L / (60 * Ks * (So)^{0.5})$

TIME OF CONCENTRATION CALCULATIONS

Existing	Status							
		Segment	Length	Ns	Ks	So%(ave)	Tt(min)	Tc Used (min.)
Impervious			40	0.011		2.5	0.7	5
Pervious	Sheet Flow		37	0.15		2	5.6	5.6
Proposed								
Impervious	Sheet Flow		16	0.011		8.3	0.2	5
Pervious	Sheet Flow		0	0.15		9.3	0.0	5

B. DEVELOPED PEAK FLOW CALCULATION:

Project Precips

[2 yr]	2.00 in
[5 yr]	2.80 in
[10 yr]	3.00 in
[25 yr]	3.50 in
[100 yr]	4.00 in
[6-mo]	1.28 in

PRE1 Event Summary:

BasinID	Peak Q (cfs)	Peak T (hrs)	Peak Vol (ac-ft)	Area ac	Method /Loss	Raintype	Event
PRE1	0.0116	7.83	0.0042	0.04	SBUH/SCS	TYPE1A	2 yr
PRE1	0.0205	7.83	0.0071	0.04	SBUH/SCS	TYPE1A	10 yr
PRE1	0.0251	7.83	0.0087	0.04	SBUH/SCS	TYPE1A	25 yr
PRE1	0.0298	7.83	0.0102	0.04	SBUH/SCS	TYPE1A	100 yr

Drainage Area: PRE1

Hyd Method:	SBUH Hyd	Loss Method:	SCS CN Number
Peak Factor:	484.00	SCS Abs:	0.20
Storm Dur:	24.00 hrs	Intv:	10.00 min
	Area	CN	TC
Pervious	0.0218 ac	86.00	0.09 hrs
Impervious	0.0179 ac	98.00	0.01 hrs
Total	0.0397 ac		

Supporting Data:

Pervious CN Data:

Lawn	86.00	0.0218 ac
------	-------	-----------

Impervious CN Data:

Driveway	98.00	0.0179 ac
----------	-------	-----------

Pervious TC Data:

Flow type:	Description:	Length:	Slope:	Coeff:	Travel Time
Sheet	Lawn	37.00 ft	2.00%	0.1500	5.59 min

Impervious TC Data:

Flow type:	Description:	Length:	Slope:	Coeff:	Travel Time
Sheet	Asphalt	40.00 ft	2.50%	0.0110	0.67 min

Dev1 Event Summary:

BasinID	Peak Q (cfs)	Peak T (hrs)	Peak Vol (ac-ft)	Area ac	Method /Loss	Raintype	Event
Dev1	0.0178	7.83	0.0059	0.04	SBUH/SCS	TYPE1A	2 yr
Dev1	0.0275	7.83	0.0092	0.04	SBUH/SCS	TYPE1A	10 yr
PRE1	0.0323	7.83	0.0087	0.04	SBUH/SCS	TYPE1A	25 yr
Dev1	0.0370	7.83	0.0125	0.04	SBUH/SCS	TYPE1A	100 yr

Drainage Area: Dev1

Hyd Method:	SBUH Hyd	Loss Method:	SCS CN Number
Peak Factor:	484.00	SCS Abs:	0.20
Storm Dur:	24.00 hrs	Intv:	10.00 min
	Area	CN	TC
Pervious	0.0000 ac	86.00	0.00 hrs
Impervious	0.0397 ac	98.00	0.00 hrs
Total	0.0397 ac		

Supporting Data:

Impervious CN Data:

Driveway+Walkway	98.00	0.0161 ac
Garage	98.00	0.0236 ac

Impervious TC Data:

Flow type:	Description:	Length:	Slope:	Coeff:	Travel Time
Sheet	Overland	16.00 ft	8.30%	0.0110	0.20 min

C. STORM DUPLEX PUMP DESIGN:

4245 90th Ave SE, Mercer Is. - STORM PUMP CAPACITY ANALYSIS

STORM WATER LIFT STATION DESIGN

A. DETERMINE THE REQUIRED RATE OF PUMPING;

100-YR PEAK FLOW, Q_{max} = 0.0298 cfs = 15.4 GPM (Allowable flow rate from ex condition - See Storm Shed Calc.)

B. COMPUTE THE STORAGE REQUIREMENT FOR THE WETWELL:

USING 2 PUMPS AND 4 CYCLES PER HOUR
TIME FOR ONE PUMP CYCLE:

$$T = (V/Q - S) + (V/S)$$

Where:

T = THE TIME FOR ONE PUMP CYCLE IN MINUTES = 60
 V = THE EFFECTIVE VOLUME OF THE WETWELL IN GALLON = V
 Q = THE PUMPING RATE IN GALLONS PER MINUTE = 15
 S = THE FLOW INTO THE WETWELL IN GALLONS PER MINUTE = 5 0.0058 cfs
 (Allowable 50% of 2-yr ex flow rate)

$$V = TS(Q - S)/Q = 193$$

USE 4 FEET DIAMETER WET WELL
 VOLUME PER FOOT = 94.00 GAL/FT
 WORKING DEPTH = 2.06 FEET = 193.49 Gallons

Availale Storage Vol., 3 feet= 281.99 GAL OK

C. DETERMINE THE FORCEMAIN DIAMETER:

Q_{max} = 15 GPM = 0.03 CFS

MAXIMUM CROSS SECTION REQUIRED = 0.01 SF
 (FOR VEL. = 3 FPS) = 1.64 SI

USE 2 INCH DIAMETER HDPE PIPE, V = Q/A
 (AREA = 0.02 SF) = 1.57 FPS ~ 3 FPS ~OK

D. DETERMINE HEAD LOSS OF HDPE FORCE MAIN:

$$H = (Q/(0.006757)(C)(D^{2.63}))^{1.85}$$

WHERE: H = THE HEAD LOSS IN FEET PER 1000 FEET OF PIPE = H
 Q = THE FLOW IN GALLON PER MINUTE = 15
 C = THE HAZEN-WILLIAM COEFFICIENT OF ROUGHNESS = 140
 D = THE PIPE DIAMETER IN INCHES = 2 USED

H = 5.96 FEET (for 2-in Diameter Pipe)

LENGTH OF PIPE = 6 FEET HEAD LOSS IN PIPE = 0 FT.

E. COMPUTE THE TOTAL DYNAMIC HEAD (TDH)

a) STATIC DISCHARGE HEAD = 5.82 FEET
 DISCHARGE ELEVATION = 368.76
 PUMP OFF ELEVATION = 362.85

b) MINOR LOSSES = 5.9
 2 - 90 DEG. ELL = 1.4
 1 - GATE VALVE = 0.2
 1 - CHECK VALVE = 2.5
 1 - TEE = 1.8

c) TOTAL DISCHARGE HEAD LOSS = 11.76 FEET

G. COMPUTE THE REQUIRED BRAKE HORSEPOWER:

$H_{pbrake} = (GPM \times TDH) / (3960 \times \text{EFF.}) = 0.076$ USE 1/3 HP SUBMERSIVE PUMP WITH
 EFF. OF 60 %

WHERE: GPM = FLOW RATE IN GALLON PER MINUTE
 TDH = TOTAL DYNAMIC HEAD OF THE SYSTEM IN FEET
 WHEN DELIVERING THE REQUIRED FLOW RATE
 3960 = A CONSTANT
 EFF = PUMP EFFICIENCY EXPRESSED IN DECIMAL FORM

D. PUMP CURVE:

Use Goulds Pump WS_BHF Series, Model WS0311 BHF (1/3 HP) or Equal.
See Plan for pump details.

