

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

The glazing (window) and door portion of this calculator assumes the installed glazing and door products have an area weighted average U-factor of 0.30. The incorporated insulation requirements are the minimum prescriptive amounts specified by the 2015 WSEC.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

Project Information

YOU CHUNG RESIDENCE
7002 78th Ave. SE Mercer Island, WA 98040

Contact Information

YOU CHUNG
425-362-0413

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference (^a T) 45
ΔT = Indoor (70 degrees) - Outdoor Design Temp

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

445

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume
3,783

Glazing and Doors

[Instructions](#)

U-Factor X Area = UA
0.30 X 147 = 44.10

U-Factor X Area = UA
0.50 X 0 = ---

Skylights

[Instructions](#)

U-Factor X Area = UA
0.026 X 0 = ---

Insulation

Attic

[Instructions](#)

R-38 Advanced

U-Factor X Area = UA
0.027 X 445 = 12.02

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
0.056 X 1,520 = 85.12

Floors

[Instructions](#)

R-30

U-Factor X Area = UA
0.029 X 445 = 12.91

Below Grade Walls (see Figure 1)

[Instructions](#)

R-10 Continuous Exterior

U-Factor X Area = UA
0.064 X 40 = 2.56

Slab Below Grade (see Figure 1)

[Instructions](#)

Select conditioning

F-Factor X Length = UA
No selection X 0 = ---

Slab on Grade (see Figure 1)

[Instructions](#)

Select R-Value

F-Factor X Length = UA
No selection X 0 = ---

Location of Ducts

[Instructions](#)

Conditioned Space

Duct Leakage Coefficient
1.00

Sum of UA 156.70

Envelope Heat Load 7,052 Btu / Hour
Sum of UA X ΔT

Air Leakage Heat Load 1,838 Btu / Hour
Volume X 0.6 X ΔT X .018

Building Design Heat Load 8,890 Btu / Hour
Air Leakage + Envelope Heat Loss

Building and Duct Heat Load 8,890 Btu / Hour
Ducts in unconditioned space: Sum of Building Heat Loss X 1.10
Ducts in conditioned space: Sum of Building Heat Loss X 1

Maximum Heat Equipment Output 12,446 Btu / Hour
Building and Duct Heat Loss X 1.40 for Forced Air Furnace
Building and Duct Heat Loss X 1.25 for Heat Pump

Figure 1.

