



Interlaken Engineering and Design, PLLC  
7001 Seaview Ave NW, Suite 160-388,  
Seattle, WA 98117 | (206) 470-9572

June 28, 2021

RE: 80XX SE 20<sup>th</sup> Street (Parcel 544930-0057)

Dear Ms. Ding:

Please find changes between the initial submittal dated March 22, 2021 and the updated submittal dated April 30, 2021 outlined below:

- 1) In response to the capacity constraint of the downstream storm drain a detention system has been added, as shown on Sheet C2, detailed on Sheet C3, and indicated on page 5 of the Stormwater Submittal.
- 2) Downspouts re-routed around house, as shown in sheet C2.

Please feel free to reach out with any questions. Thank you.

Sincerely,

Matthew J. Haringa, P.E.  
Principal  
Interlaken Engineering and Design, PLLC