

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Forest Ave Lot 3
5208 Forest Ave SE
Mercer Island, WA 98040

Contact Information

Kati Eitzman - Sturman Architects
9- 103rd Ave NE Ste. 203
Bellevue, WA 98004

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

Instructions

Mercer Island

Design Temperature Difference (ΔT) 45
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

Instructions

Conditioned Floor Area (sq ft)

6,272

Average Ceiling Height

Instructions

Average Ceiling Height (ft)

9.3

Conditioned Volume
58,330

Glazing and Doors

Instructions

U-0.28

U-Factor X Area = UA
0.280 X 1,008 = 282.24

Skylights

Instructions

U-Factor X Area = UA
0.50 X 44 = 22.00

Insulation

Attic

Instructions

Select R-Value

U-Factor X Area = UA
No selection = ---

Single Rafter or Joist Vaulted Ceilings

Instructions

R-49 Advanced

U-Factor X Area = UA
0.020 X 3,092 = 61.84

Above Grade Walls (see Figure 1)

Instructions

R-21 Intermediate

U-Factor X Area = UA
0.056 X 4,799 = 268.74

Floors

Instructions

R-38

U-Factor X Area = UA
0.025 X 701 = 17.53

Below Grade Walls (see Figure 1)

Instructions

R-21 Interior

U-Factor X Area = UA
0.042 X 1,674 = 70.31

Slab Below Grade (see Figure 1)

Instructions

R-21 int Plus R-5 ci

F-Factor X Length = UA
0.303 X 189 = 57.27

Slab on Grade (see Figure 1)

Instructions

No Slab on Grade in this project.

F-Factor X Length = UA
--- = ---

Location of Ducts

Instructions

Conditioned Space

Duct Leakage Coefficient
1.00

| | |
|---|-------------------|
| Sum of UA | 779.92 |
| Envelope Heat Load | 35,097 Btu / Hour |
| <i>Sum of UA x ΔT</i> | |
| Air Leakage Heat Load | 28,348 Btu / Hour |
| <i>Volume x 0.6 x ΔT x 0.018</i> | |
| Building Design Heat Load | 63,445 Btu / Hour |
| <i>Air leakage + envelope heat loss</i> | |
| Building and Duct Heat Load | 63,445 Btu / Hour |
| <i>Ducts in unconditioned space: sum of building heat loss x 1.10</i> | |
| <i>Ducts in conditioned space: sum of building heat loss x 1</i> | |
| Maximum Heat Equipment Output | 79,306 Btu / Hour |
| <i>Building and duct heat loss x 1.40 for forced air furnace</i> | |
| <i>Building and duct heat loss x 1.25 for heat pump</i> | |

Figure 1.

