	Reviewer					
INTAKE COMMENTS	Email					
FIRE	Status					
11112	Submittal					
Fire Requirements						
Fire Sprinkler System						
☐ Required		Not Required	1		Not yet Determined	
□ NFPA 13D			NFPA 13			
☐ NFPA 13D Plus	□ NFPA 13D Plus NFPA 13R					
Monitored Household Fire Alarm per NFPA 72						
☐ Required		Not Required	l		Not Yet Determined	
Monitored Sprinkler Water Flo		•				
Required		Not Required	1		Not Yet Determined	
☐ A Fire Code Alternative is required. Please review the <u>Fire Code Alternative Request</u> handout for more						
information. The Fire Marshal's Office will email you a Fire Review Document that outlines the specific fire						
service deficiencies related to your project. You will need to include this information in your request. Fire						
Code Alternative Request submittals will be accepted at any time during the plan review process.						
A final determination has not yet been made as to the fire requirements for this project. The fire						
requirements will be determined during permit review.						
Additional notes:						
Notes to DSG Staff For Internal Use Only–No Applicant Response Required						
П						