

**Monday, November 1, 2021**

**Mercer Island  
Permit No. 2108-113**

**MERCER ISLAND  
Response to Second Intake  
Screening**

**Fire Marshal Jeromy Hicks**  
[Jeromy.hicks@mercerisland.gov](mailto:Jeromy.hicks@mercerisland.gov)  
206-275-7966

**Confirm that 13d will be installed. This will require a separate permit and may be deferred. Please indicate this on the plan set.**

*RESPONSE: Fire sprinkler system notes added to sheet A1, A2.*

**Smoke detectors and/or sounders must activate upon waterflow of the fire sprinkler system. Please indicate this on the plan set.**

*RESPONSE: Fire sprinkler system notes added to sheet A1, A2.*