

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

Project Information

Mounger Residence
 4006 E. Mercer Way
 Mercer Island, WA 98040

Contact Information

Brad Sturman - Sturman Architects
 9 103rd Ave NE Suite 203
 Bellevue, WA 98004

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

Design Temperature

Instructions

Mercer Island

Design Temperature Difference (ΔT) 45
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

Instructions

Conditioned Floor Area (sq ft)

4,327

Average Ceiling Height

Instructions

Average Ceiling Height (ft)

8.1

Conditioned Volume
 35,049

Glazing and Doors

Instructions

U-0.30

U-Factor X Area = UA
 0.300 X 707 = 212.07

Skylights

Instructions

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

Instructions

R-49

U-Factor X Area = UA
 0.026 X 1,713 = 44.53

Single Rafter or Joist Vaulted Ceilings

Instructions

R-49 Advanced

U-Factor X Area = UA
 0.020 X 438 = 8.76

Above Grade Walls (see Figure 1)

Instructions

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,892 = 161.95

Floors

Instructions

R-30

U-Factor X Area = UA
 0.029 X 2,461 = 71.38

Below Grade Walls (see Figure 1)

Instructions

R-21 Interior

U-Factor X Area = UA
 0.042 X 511 = 21.48

Slab Below Grade (see Figure 1)

Instructions

R-10 Fully insulated

F-Factor X Length = UA
 0.303 X 0 = ---

Slab on Grade (see Figure 1)

Instructions

Select R-Value

F-Factor X Length = UA
 No selection X 0 = ---


Location of Ducts

Instructions

Unconditioned Space

Duct Leakage Coefficient
 1.10

Figure 1.



Sum of UA	520.16
Envelope Heat Load	23,407 Btu / Hour
<i>Sum of UA X ΔT</i>	
Air Leakage Heat Load	17,034 Btu / Hour
<i>Volume X 0.6 X ΔT X .018</i>	
Building Design Heat Load	40,441 Btu / Hour
<i>Air Leakage + Envelope Heat Loss</i>	
Building and Duct Heat Load	44,485 Btu / Hour
<i>Ducts in unconditioned space: Sum of Building Heat Loss X 1.10</i>	
<i>Ducts in conditioned space: Sum of Building Heat Loss X 1</i>	
Maximum Heat Equipment Output	55,606 Btu / Hour
<i>Building and Duct Heat Loss X 1.40 for Forced Air Furnace</i>	
<i>Building and Duct Heat Loss X 1.25 for Heat Pump</i>	