

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Bird McDonald Residence
 4304 E Mercer Way
 Mercer Island, WA 98040

Contact Information

Karen Kline, McClellan Architects
 karen@mccarch.com
 206-728-0480

Heating System Type:

- All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference (ΔT)

45

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

3,552

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.5

Conditioned Volume

33,744

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
 0.280 X 1,105 = 309.40

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 0 = ---

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X 0 = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA
 0.027 X 1,492 = 40.28

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 1,036 = 58.02

Floors

[Instructions](#)

R-30

U-Factor X Area = UA
 0.029 X 2,116 = 61.36

Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA
 0.042 X 456 = 19.15

Slab Below Grade (see Figure 1)

[Instructions](#)

R-10 Fully insulated

F-Factor X Length = UA
 0.303 X 108 = 32.72

Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Perimeter

F-Factor X Length = UA
 0.540 X 82 = 44.28


Location of Ducts

[Instructions](#)

Unconditioned Space

Duct Leakage Coefficient

1.10



Sum of UA	565.22
Envelope Heat Load	25,435 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	16,400 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	41,834 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	46,018 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	57,522 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	