

## Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

### Project Information

Koneru Residence  
6610 E Mercer Way  
Mercer Island, WA

### Contact Information

Devlin Rose  
McCullough Architects

**Heating System Type:**  All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference ( $\Delta T$ ) 45  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

9,966

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

11.0

Conditioned Volume  
109,626

### Glazing and Doors

[Instructions](#)

U-0.28

**U-Factor X Area = UA**  
0.280 X 4,153 = 1162.84

### Skylights

[Instructions](#)

**U-Factor X Area = UA**  
0.50 X 150 = 75.00

### Insulation

#### Attic

[Instructions](#)

Select R-Value

**U-Factor X Area = UA**  
No selection X = ---

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Unvented

**U-Factor X Area = UA**  
0.027 X 6,177 = 166.78

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

**U-Factor X Area = UA**  
0.056 X 4,788 = 268.13

#### Floors

[Instructions](#)

R-38

**U-Factor X Area = UA**  
0.025 X 658 = 16.45

#### Below Grade Walls (see Figure 1)

[Instructions](#)

Select R-value

**U-Factor X Area = UA**  
No selection X = ---

#### Slab Below Grade (see Figure 1)

[Instructions](#)

Select conditioning

**F-Factor X Length = UA**  
No selection X = ---

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

**F-Factor X Length = UA**  
0.360 X 5,498 = 1979.28


### Location of Ducts

[Instructions](#)

Conditioned Space

**Duct Leakage Coefficient**  
1.00

Figure 1.



<b>Sum of UA</b>	3668.48
<b>Envelope Heat Load</b>	165,081 Btu / Hour
<i>Sum of UA x <math>\Delta T</math></i>	
<b>Air Leakage Heat Load</b>	53,278 Btu / Hour
<i>Volume x 0.6 x <math>\Delta T</math> x 0.018</i>	
<b>Building Design Heat Load</b>	218,360 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
<b>Building and Duct Heat Load</b>	218,360 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
<b>Maximum Heat Equipment Output</b>	272,950 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	