



Date: July 27, 2022

To: Jacob Halverson, Building Plans Examiner  
Department of Community Planning & Development  
City of Mercer Island  
9611 SE 36th St.  
Mercer Island, WA 98040

RE: Alfresco Product installation for Ralph & Katharine Brindley,  
78xx – 79th Ave. SE, Mercer Island, WA 98040

In regard to the use of an Alfresco Outdoor Kitchen Product located at above address. The use of a ventilation hood approved for outdoor use, with a minimum of 1200 CFM blower, is an acceptable ventilation to be placed over the Alfresco Grill when installed under a roof for this specific application. The other clearances to combustible materials at the back and sides are still required to be maintained as set forth in the Alfresco installation and care and use manuals.

Should you have additional questions or concerns please feel free to reach out to me directly.

Sincerely,

*Art Valentine*

**Art Valentine**  
Executive Vice President  
SES Brands / Alfresco / Artisan  
1085 Bixby Dr.  
City of Industry, CA 91745  
Cell (786) 298-7640  
[avalentine@sesbrands.com](mailto:avalentine@sesbrands.com)