

0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00

Sum of Vertical Fenestration Area and UA
Vertical Fenestration Area Weighted U = UA/Area

540.9	108.18
	0.20

Overhead Glazing (Skylights)

Component Description	Ref.	U-factor

Qt.	Width		Height	
	Feet	Inch	Feet	Inch

Area	UA
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00
0.0	0.00

Sum of Overhead Glazing Area and UA
Overhead Glazing Area Weighted U = UA/Area

0.0	0.00
	0.00

Total Sum of Fenestration Area and UA (for heating system sizing calculations)

540.9	108.18
-------	--------

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Contact Information

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Design Temperature Difference (ΔT) 45

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

Conditioned Volume

42,380

Glazing and Doors

[Instructions](#)

U-Factor X Area = UA
0.200 X 541 = 108.20

Skylights

[Instructions](#)

U-Factor X Area = UA
0.50 X [] = ---

Insulation

Attic

[Instructions](#)

U-Factor X Area = UA
0.026 X 1,813 = 47.14

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

U-Factor X Area = UA
No selection X [] = ---

Above Grade Walls (see Figure 1)

[Instructions](#)

U-Factor X Area = UA
0.056 X 3,275 = 183.40

Floors

[Instructions](#)

U-Factor X Area = UA
0.025 X 2,053 = 51.33

Below Grade Walls (see Figure 1)

[Instructions](#)

U-Factor X Area = UA
No selection X [] = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

F-Factor X Length = UA
No selection X [] = ---

Slab on Grade (see Figure 1)

[Instructions](#)


F-Factor X Length = UA
No selection X [] = ---

Location of Ducts

[Instructions](#)

Duct Leakage Coefficient

1.00



Sum of UA	390.06
Envelope Heat Load	17,553 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	20,596 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	38,149 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	38,149 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	47,687 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	