

# Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

### Project Information

Simpson Residence  
6454 E Mercer Way  
Mercer Island, WA 98004

### Contact Information

Brad Sturman - Sturman Architects  
9 103rd Ave NE Suite 203  
Bellevue, WA 98040

### Heating System Type:

All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

### Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference ( $\Delta T$ ) 45  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

### Area of Building

#### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

4,789

#### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.5

Conditioned Volume

45,498

### Glazing and Doors

[Instructions](#)

U-0.28

**U-Factor X Area = UA**  
0.280 X 1,058 = 296.21

### Skylights

[Instructions](#)

**U-Factor X Area = UA**  
0.50 X 0 = ---

### Insulation

#### Attic

[Instructions](#)

R-49

**U-Factor X Area = UA**  
0.026 X 2,240 = 58.23

#### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

**U-Factor X Area = UA**  
0.027 X 1,081 = 29.19

#### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

**U-Factor X Area = UA**  
0.056 X 5,094 = 285.24

#### Floors

[Instructions](#)

R-38

**U-Factor X Area = UA**  
0.025 X 2,051 = 51.28

#### Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

**U-Factor X Area = UA**  
0.028 X --- = ---

#### Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

**F-Factor X Length = UA**  
0.303 X --- = ---

#### Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Perimeter

**F-Factor X Length = UA**  
0.540 X 21 = 11.07


### Location of Ducts

[Instructions](#)

Unconditioned Space

Duct Leakage Coefficient

1.10



<b>Sum of UA</b>	731.22
<b>Envelope Heat Load</b>	32,905 Btu / Hour
<i>Sum of UA x <math>\Delta T</math></i>	
<b>Air Leakage Heat Load</b>	22,112 Btu / Hour
<i>Volume x 0.6 x <math>\Delta T</math> x 0.018</i>	
<b>Building Design Heat Load</b>	55,017 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
<b>Building and Duct Heat Load</b>	60,519 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
<b>Maximum Heat Equipment Output</b>	75,649 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	