

March 03, 2023

ATTN:

Ruji Ding- Civil
Gareth Reece- Building

RE: Intake Screening- 2206-040
Project: 9191 SE 64th st. new SFR.

Good morning,

Please find our responses to your intake comments:

1. Ruji Ding-Civil plan shows proposed drainage system on neighboring property to south. Provide recorded easement or written agreement from property owner.
Written agreement for easement included in resubmittal docs. Property to the south is also owned by this property owner if that makes things easier.
2. Gareth Reece- Recommendations and design for a shoring wall are included in the supplemental documents, but these components need to be documented in the construction set.
Shoring wall docs added to the construction set.

Let us know if there are any other questions we can help clarify. Thanks so much!

Curtis Heard
559-593-2038
curtisheard@sbcglobal.net