

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

RADER RESIDENCE
7310 86TH AVE SE
MERCER ISLAND, WA 98040

Contact Information

H2D ARCHITECTURE + DESIGN
23020 EDMONDS WAY #113
EDMONDS WA 98020

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Seattle: Sea-Tac AP

Design Temperature Difference (ΔT)

46

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

4,019

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

7.6

Conditioned Volume

30,542

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
0.280 X 662 = 185.44

Skylights

[Instructions](#)

U-Factor X Area = UA
0.50 X [] = ---

Insulation

Attic

[Instructions](#)

R-49

U-Factor X Area = UA
0.026 X 2,620 = 68.11

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA
0.027 X 207 = 5.58

Above Grade Walls (see Figure 1)

[Instructions](#)

Select R-Value

U-Factor X Area = UA
No selection X 2,646 = ---

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
0.025 X 2,591 = 64.77

Below Grade Walls (see Figure 1)

[Instructions](#)

No Below Grade Walls in this project.

U-Factor X Area = UA
0.028 X [] = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

No Slab Below Grade in this project.

F-Factor X Length = UA
0.303 X [] = ---

Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA
--- X [] = ---

Location of Ducts


[Instructions](#)

Unconditioned Space

Duct Leakage Coefficient

1.10

Figure 1.



| | |
|-----------------------------------------------------------------------|-------------------|
| Sum of UA | 323.90 |
| Envelope Heat Load | 14,900 Btu / Hour |
| <i>Sum of UA x ΔT</i> | |
| Air Leakage Heat Load | 15,173 Btu / Hour |
| <i>Volume x 0.6 x ΔT x 0.018</i> | |
| Building Design Heat Load | 30,073 Btu / Hour |
| <i>Air leakage + envelope heat loss</i> | |
| Building and Duct Heat Load | 33,080 Btu / Hour |
| <i>Ducts in unconditioned space: sum of building heat loss x 1.10</i> | |
| <i>Ducts in conditioned space: sum of building heat loss x 1</i> | |
| Maximum Heat Equipment Output | 41,350 Btu / Hour |
| <i>Building and duct heat loss x 1.40 for forced air furnace</i> | |
| <i>Building and duct heat loss x 1.25 for heat pump</i> | |