

CITY OF MERCER ISLAND

COMMUNITY PLANNING & DEVELOPMENT

9611 SE 36TH STREET | MERCER ISLAND, WA 98040

PHONE: 206.275.7605 | www.mercergov.org

Inspection Requests: Online: www.mybuildingpermit.com VM: 206.275.7730



SIDE SEWER VIDEO INSPECTION REPORT

PROPERTY OWNER INFORMATION

Applicant/Contact:	<u>Kali Rushing</u>	Phone:	<u>509-954-8623</u>
Site Address:	<u>3015 70th Ave SE</u>		
Mailing Address:			
Building Type:	<u>Single Family</u>	Multi Family	Commercial

CONTRACTOR INFORMATION

Contractor/Contact:	<u>Jeremy Grookstetter</u>	Phone:	<u>206-402-7739</u>
Address:	<u>P.O. Box 68133 Seattle, WA 98168</u>		
Email Address:	<u>customer service @ Pinkys plumbing.biz</u>		
Name of Technician:	<u>Jeremy</u>		
Date of Inspection:	<u>04/04/2023</u>	Weather Condition:	<u>Fair</u>

INFLOW INSPECTION

Are there any sources of inflow entering the sanitary sewer system:	Yes	<u>No</u>
If yes, check all that apply:	Sump Pump	Basement Area Drain
	Downspouts	
	Footing/Foundation Drain	Driveway Drain
	Other:	

PRIVATE SIDE SEWER INSPECTION RESULTS

TV Direction:	Upstream	<u>Downstream</u>	Total video Footage:	<u>101 feet</u>
Pipe Material (check all that applies)	A/C	<u>Concrete</u>	Cast/Ductile	PVC/ABS
	Other:			
Pipe Diameter:	3"	<u>4"</u>	6"	8"
Cleanouts:	<u>Yes</u>	No	If yes, location:	<u>Downstairs Closet</u>
Is this side sewer shared with neighboring properties?	<u>Yes</u>	No		
If yes, please list addresses:	<u>3030 69th Ave SE</u>			

Please complete reverse side

CONDITION OF LATERAL - OBSERVATIONS		
Observation Key: (H-Hole, SV-Soil Visible, EA-Exposed Aggregate, R-Roots, OJ-Offset Joint, C-Cracks, G-Grease/Blockage, S-Sag)		
Footage	Observation	Comments
101feet	EA	

ADDITIONAL COMMENTS REGARDING CONDITION OF LATERAL

Signature Jeremy Gookstetter Date 04/27/2023

Print Name Jeremy Gookstetter

SKETCH

CITY OF MERCER ISLAND

COMMUNITY PLANNING & DEVELOPMENT

9611 SE 36TH STREET | MERCER ISLAND, WA 98040

PHONE: 206.275.7605 | www.mercergov.org

Inspection Requests: Online: www.mybuildingpermit.com VM: 206.275.7730



SIDE SEWER VIDEO INSPECTION REPORT

PROPERTY OWNER INFORMATION		
Applicant/Contact:	Kali Rushing	Phone: 509-954-8623
Site Address:	3030 69th Ave SE	
Mailing Address:		
Building Type:	<input checked="" type="radio"/> Single Family	<input type="radio"/> Multi Family <input type="radio"/> Commercial

CONTRACTOR INFORMATION		
Contractor/Contact:	Jeremy Crookstetter	Phone: 206-402-7739
Address:	PO Box 68133	
Email Address:	customerservice@pinkysplumbing.biz	
Name of Technician:	Jeremy	
Date of Inspection:	04/04/2023	Weather Condition: fair

INFLOW INSPECTION			
Are there any sources of inflow entering the sanitary sewer system:	Yes	<input checked="" type="radio"/> No	
If yes, check all that apply:	<input type="checkbox"/> Sump Pump	<input type="checkbox"/> Basement Area Drain	<input type="checkbox"/> Downspouts
	<input type="checkbox"/> Footing/Foundation Drain	<input type="checkbox"/> Driveway Drain	<input type="checkbox"/> Other:

PRIVATE SIDE SEWER INSPECTION RESULTS				
TV Direction:	<input type="checkbox"/> Upstream	<input checked="" type="checkbox"/> Downstream	Total video Footage:	88 feet
Pipe Material (check all that applies)	<input checked="" type="checkbox"/> A/C	<input checked="" type="checkbox"/> Concrete	<input type="checkbox"/> Cast/Ductile	<input type="checkbox"/> PVC/ABS
Pipe Diameter:	<input type="checkbox"/> 3"	<input checked="" type="checkbox"/> 4"	<input type="checkbox"/> 6"	<input type="checkbox"/> 8"
Cleanouts:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	If yes, location:	Front Yard
Is this side sewer shared with neighboring properties?	<input checked="" type="checkbox"/> Yes		<input type="checkbox"/> No	
If yes, please list addresses:	3015 70th Ave SE			

Please complete reverse side

CONDITION OF LATERAL - OBSERVATIONS		
Observation Key: (H-Hole, SV-Soil Visible, EA-Exposed Aggregate, R-Roots, OJ-Offset Joint, C-Cracks, G-Grease/Blockage, S-Sag)		
Footage	Observation	Comments
88 feet	EA	

ADDITIONAL COMMENTS REGARDING CONDITION OF LATERAL

Signature Jeremy Grooksteter Date 04/27/2023

Print Name Jeremy Grooksteter

SKETCH
