

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Knotz Residence
6020 94th Ave SE
Mercer Island, WA 98040

Contact Information

Brad Sturman - Sturman Architects
9 103rd Ave NE Suite 203
Bellevue, WA 98004

Heating System Type:

All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Bellevue

Design Temperature Difference (ΔT)
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

841

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

10.5

Conditioned Volume
8,827

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
0.280 X 286 = 80.11

U-Factor X Area = UA
0.50 X 70 = 35.00

Skylights

[Instructions](#)

Insulation

Attic

[Instructions](#)

R-49

U-Factor X Area = UA
0.026 X 436 = 11.34

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

U-Factor X Area = UA
0.027 X 1,287 = 34.75

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
0.056 X 747 = 41.82

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
0.025 X 841 = 21.03

Below Grade Walls (see Figure 1)

[Instructions](#)

Select R-value

U-Factor X Area = UA
No selection = ---

Slab Below Grade (see Figure 1)

[Instructions](#)

Select conditioning

F-Factor X Length = UA
No selection = ---

Slab on Grade (see Figure 1)

[Instructions](#)

Select R-Value

F-Factor X Length = UA
No selection = ---

Location of Ducts

[Instructions](#)

Unconditioned Space

Duct Leakage Coefficient

1.10




Figure 1.

Sum of UA	224.04
Envelope Heat Load	10,306 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	4,385 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	14,691 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	16,161 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	20,201 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	