

# Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

## Project Information

Litchfield Residence  
 9001 SE 50th ST  
 Mercer island, WA 98040

## Contact Information

Brad Sturman - Sturman Architects  
 9 103rd Ave NE Suite 203  
 Bellevue, WA 98004

## Heating System Type:

All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

## Design Temperature

[Instructions](#)

Bellevue

Design Temperature Difference ( $\Delta T$ )  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

46

## Area of Building

### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

1,437

### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.4

Conditioned Volume  
 12,039

## Glazing and Doors

[Instructions](#)

U-0.28

**U-Factor X Area = UA**  
 0.280 X 225 = 62.86

## Skylights

[Instructions](#)

**U-Factor X Area = UA**  
 0.50 X 16 = 8.00

## Insulation

### Attic

[Instructions](#)

R-49

**U-Factor X Area = UA**  
 0.026 X 1,130 = 29.39

### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Vented

**U-Factor X Area = UA**  
 0.027 X 69 = 1.86

### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

**U-Factor X Area = UA**  
 0.056 X 1,835 = 102.73

### Floors

[Instructions](#)

R-38

**U-Factor X Area = UA**  
 0.025 X 1,063 = 26.57

### Below Grade Walls (see Figure 1)

[Instructions](#)

Select R-value

**U-Factor X Area = UA**  
 No selection = ---

### Slab Below Grade (see Figure 1)

[Instructions](#)

Select conditioning

**F-Factor X Length = UA**  
 No selection = ---

### Slab on Grade (see Figure 1)

[Instructions](#)

Select R-Value

**F-Factor X Length = UA**  
 No selection = ---

## Location of Ducts

[Instructions](#)

Unconditioned Space

## Duct Leakage Coefficient

1.10




Figure 1.

|   |                   |
|---|-------------------|
| <b>Sum of UA</b>  | 231.41            |
| <b>Envelope Heat Load</b>   | 10,645 Btu / Hour |
| <i>Sum of UA x <math>\Delta T</math></i>                              |                   |
| <b>Air Leakage Heat Load</b>  | 5,981 Btu / Hour  |
| <i>Volume x 0.6 x <math>\Delta T</math> x 0.018</i>                   |                   |
| <b>Building Design Heat Load</b>                                      | 16,626 Btu / Hour |
| <i>Air leakage + envelope heat loss</i>                               |                   |
| <b>Building and Duct Heat Load</b>                                    | 18,289 Btu / Hour |
| <i>Ducts in unconditioned space: sum of building heat loss x 1.10</i> |                   |
| <i>Ducts in conditioned space: sum of building heat loss x 1</i>      |                   |
| <b>Maximum Heat Equipment Output</b>                                  | 22,861 Btu / Hour |
| <i>Building and duct heat loss x 1.40 for forced air furnace</i>      |                   |
| <i>Building and duct heat loss x 1.25 for heat pump</i>               |                   |