

# Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at [energycode@energy.wsu.edu](mailto:energycode@energy.wsu.edu) or (360) 956-2042 for assistance.

## Project Information

Madrona Crest  
3605 86th Ave SE  
Mercer Island, WA, 98040

## Contact Information

Dan Gonzalez, PM, First Lamp ([dan@firstlamp.net](mailto:dan@firstlamp.net))  
4915 Rainier Ave S, STE 202  
Seattle, WA, 98118

**Heating System Type:**  All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

## Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference ( $\Delta T$ ) 45  
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

## Area of Building

### Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

3,213

### Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.5

Conditioned Volume  
30,521

## Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA  
0.280 X 888 = 248.64

## Skylights

[Instructions](#)

U-Factor X Area = UA  
0.50 X 0 = ---

## Insulation

### Attic

[Instructions](#)

R-49

U-Factor X Area = UA  
0.026 X 2,419 = 62.89

### Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

No Vaulted Ceilings in this project.

U-Factor X Area = UA  
--- X 0 = ---

### Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 4,223 = 236.50

### Floors

[Instructions](#)

R-38

U-Factor X Area = UA  
0.025 X 1,777 = 44.43

### Below Grade Walls (see Figure 1)

[Instructions](#)

R-21 Interior

U-Factor X Area = UA  
0.042 X 0 = ---

### Slab Below Grade (see Figure 1)

[Instructions](#)

R-21 int Plus R-5 ci

F-Factor X Length = UA  
0.303 X 0 = ---

### Slab on Grade (see Figure 1)

[Instructions](#)

No Slab on Grade in this project.

F-Factor X Length = UA  
--- X 0 = ---

## Location of Ducts

[Instructions](#)

Conditioned Space

Duct Leakage Coefficient  
1.00




Figure 1.

<b>Sum of UA</b>	592.47
<b>Envelope Heat Load</b>	26,661 Btu / Hour
<i>Sum of UA x <math>\Delta T</math></i>	
<b>Air Leakage Heat Load</b>	14,833 Btu / Hour
<i>Volume x 0.6 x <math>\Delta T</math> x 0.018</i>	
<b>Building Design Heat Load</b>	41,494 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
<b>Building and Duct Heat Load</b>	41,494 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
<b>Maximum Heat Equipment Output</b>	51,868 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	