

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Ehrhardt Remodel
8456 N Mercer Way
Mercer Island, WA 98040

Contact Information

Brad Sturman
9 103rd Ave NE Suite 203
Bellevue, WA 98040

Heating System Type:

All Other Systems

Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Mercer Island

Design Temperature 25

Design Temperature Difference (ΔT) 45

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

4,582

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

8.5

Conditioned Volume

38,947

Glazing and Doors

[Instructions](#)

U-0.28

U-Factor X Area = UA
0.280 X 876 = 245.34

Skylights

[Instructions](#)

U-Factor X Area = UA
0.50 X 64 = 32.00

Insulation

Attic

[Instructions](#)

R-49

U-Factor X Area = UA
0.026 X 1,561 = 40.59

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-38 Advanced

U-Factor X Area = UA
0.026 X 1,240 = 32.24

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
0.056 X 2,601 = 145.66

Floors

[Instructions](#)

R-38

U-Factor X Area = UA
0.025 X 891 = 22.28

Below Grade Walls and Slabs (see Figure 1)

[Instructions](#)

Wall & Slab R21 Batt w/TB

Depth 3.5' depth

Wall U-Factor X Area = UA
0.040 X 713 = 28.52

Slab F-Factor X Length = UA
0.560 X 216 = 120.96

Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Fully Insulated

F-Factor X Length = UA
0.360 X 1,781 = 641.16

Location of Ducts

[Instructions](#)

Conditioned Space

Duct Leakage Coefficient

1.000

Sum of UA 1308.73

Envelope Heat Load 58,893 Btu / Hour

$\text{Sum of UA} \times \Delta T$

Air Leakage Heat Load 18,928 Btu / Hour

$\text{Volume} \times 0.6 \times \Delta T \times 0.018$

Building Design Heat Load 77,821 Btu / Hour

$\text{Air leakage} + \text{envelope heat loss}$

Building and Duct Heat Load 77,821 Btu / Hour

$\text{Ducts in unconditioned space: sum of building heat loss} \times 1.10$

$\text{Ducts in conditioned space: sum of building heat loss} \times 1$

Maximum Heat Equipment Output 97,277 Btu / Hour

$\text{Building and duct heat loss} \times 1.40 \text{ for forced air furnace}$

$\text{Building and duct heat loss} \times 1.25 \text{ for heat pump}$

Figure 1.

