

# Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2015 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This calculator will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

The glazing (window) and door portion of this calculator assumes the installed glazing and door products have an area weighted average U-factor of 0.30. The incorporated insulation requirements are the minimum prescriptive amounts specified by the 2015 WSEC.

Please fill out all of the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please call the WSU Energy Extension Program at (360) 956-2042 for assistance.

## Project Information

CHAN ADU  
7036 81ST AVE SE MERCER ISLAND 98040

## Contact Information

STEPHANIE WASCHA, AIA  
206.818.2139  
SW@WASCHASTUDIOS.COM

### Heating System Type:

All Other Systems  Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions".

### Design Temperature

Instructions

Mercer Island

Design Temperature Difference ( $\Delta T$ ) 45

$\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

### Area of Building

#### Conditioned Floor Area

Instructions

Conditioned Floor Area (sq ft)

900

#### Average Ceiling Height

Instructions

Average Ceiling Height (ft)

10.6

Conditioned Volume

9,540

### Glazing and Doors

Instructions

U-Factor X Area = UA  
0.30 X 167 = 50.19

U-Factor X Area = UA  
0.50 X 21 = 10.50

### Skylights

Instructions

U-Factor X Area = UA  
0.026 X 134 = 3.48

### Insulation

#### Attic

Instructions

R-49

U-Factor X Area = UA  
0.027 X 766 = 20.68

#### Single Rafter or Joist Vaulted Ceilings

Instructions

R-38 Vented

#### Above Grade Walls (see Figure 1)

Instructions

R-21 Intermediate

U-Factor X Area = UA  
0.056 X 1,114 = 62.38

#### Floors

Instructions

Select R-Value

U-Factor X Area = UA  
No selection X = ---

#### Below Grade Walls (see Figure 1)

Instructions

Select R-value

U-Factor X Area = UA  
No selection X = ---

#### Slab Below Grade (see Figure 1)

Instructions

Select conditioning

F-Factor X Length = UA  
No selection X = ---

#### Slab on Grade (see Figure 1)

Instructions

R-10 Fully Insulated

F-Factor X Length = UA  
0.360 X 139 = 50.04

### Location of Ducts

Instructions

Unconditioned Space

### Duct Leakage Coefficient

1.10

Sum of UA 197.28

Envelope Heat Load 8,877 Btu / Hour

$\text{Sum of UA} \times \Delta T$

Air Leakage Heat Load 4,636 Btu / Hour

$\text{Volume} \times 0.6 \times \Delta T \times .018$

Building Design Heat Load 13,514 Btu / Hour

$\text{Air Leakage} + \text{Envelope Heat Loss}$

Building and Duct Heat Load 14,865 Btu / Hour

$\text{Ducts in unconditioned space: Sum of Building Heat Loss} \times 1.10$

$\text{Ducts in conditioned space: Sum of Building Heat Loss} \times 1$

Maximum Heat Equipment Output 18,582 Btu / Hour

$\text{Building and Duct Heat Loss} \times 1.40 \text{ for Forced Air Furnace}$

$\text{Building and Duct Heat Loss} \times 1.25 \text{ for Heat Pump}$




Figure 1.