

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

American Classic Homes - SE 20th Residence
 80xx SE 20th Street
 Mercer Island, WA 98040

Contact Information

CW Design, Inc
 PO Box 476
 Renton, WA 98057

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

Instructions Mercer Island

Design Temperature Difference (ΔT) 45
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

Instructions Conditioned Floor Area (sq ft) 3,832

Average Ceiling Height

Instructions Average Ceiling Height (ft) 9.3

Conditioned Volume 35,638

Glazing and Doors

Instructions U-0.28

U-Factor X Area = UA
 0.280 X 765 = 214.28

Skylights

Instructions 0.50

U-Factor X Area = UA
 0.50 X [] = ---

Insulation

Attic

Instructions R-49

U-Factor X Area = UA
 0.026 X 2,625 = 68.25

Single Rafter or Joist Vaulted Ceilings

Instructions No Vaulted Ceilings in this project.

U-Factor X Area = UA
 --- X [] = ---

Above Grade Walls (see Figure 1)

Instructions R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,937 = 164.47

Floors

Instructions R-38

U-Factor X Area = UA
 0.025 X 2,639 = 65.98

Below Grade Walls (see Figure 1)

Instructions No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028 X [] = ---

Slab Below Grade (see Figure 1)

Instructions No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303 X [] = ---

Slab on Grade (see Figure 1)

Instructions No Slab on Grade in this project.

F-Factor X Length = UA
 --- X [] = ---

Location of Ducts

Instructions Conditioned Space

Duct Leakage Coefficient
 1.00

Sum of UA 512.98

Envelope Heat Load 23,084 Btu / Hour

Sum of UA x ΔT

Air Leakage Heat Load 17,320 Btu / Hour

Volume x 0.6 x ΔT x 0.018

Building Design Heat Load 40,404 Btu / Hour

Air leakage + envelope heat loss

Building and Duct Heat Load 40,404 Btu / Hour

Ducts in unconditioned space: sum of building heat loss x 1.10

Ducts in conditioned space: sum of building heat loss x 1

Maximum Heat Equipment Output 50,505 Btu / Hour

Building and duct heat loss x 1.40 for forced air furnace

Building and duct heat loss x 1.25 for heat pump

Figure 1.

