

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Lanctot Residence - DADU
 4603 89th Ave SE
 Mercer Island, WA 98040

Contact Information

Kati Eitzman - Sturman Architects
 9- 103rd Ave NE Ste. 203
 Bellevue, WA 98004

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#) Mercer Island

Design Temperature Difference (ΔT) 45
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#) Conditioned Floor Area (sq ft) 421

Average Ceiling Height

[Instructions](#) Average Ceiling Height (ft) 12.0

Conditioned Volume 5,057

Glazing and Doors

[Instructions](#) U-0.28

U-Factor X Area = UA
 0.280 X 219 = 61.32

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 29 = 14.65

Insulation

Attic

[Instructions](#) R-49

U-Factor X Area = UA
 0.026 X 460 = 11.96

Single Rafter or Joist Vaulted Ceilings

[Instructions](#) No Vaulted Ceilings in this project.

U-Factor X Area = UA

Above Grade Walls (see Figure 1)

[Instructions](#) R-21 Intermediate

U-Factor X Area = UA
 0.056 X 864 = 48.38

Floors

[Instructions](#) No Floors above unconditioned spaces.

U-Factor X Area = UA

Below Grade Walls (see Figure 1)

[Instructions](#) No Below Grade Walls in this project.

U-Factor X Area = UA
 0.028

Slab Below Grade (see Figure 1)

[Instructions](#) No Slab Below Grade in this project.

F-Factor X Length = UA
 0.303

Slab on Grade (see Figure 1)

[Instructions](#) R-10 Fully Insulated


F-Factor X Length = UA
 0.360 X 421 = 151.56

Location of Ducts

[Instructions](#) Conditioned Space

Duct Leakage Coefficient
 1.00

Figure 1.



Sum of UA	287.87
Envelope Heat Load	12,954 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	2,458 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	15,412 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	15,412 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	19,265 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	