

Simple Heating System Size: Washington State

This heating system sizing calculator is based on the Prescriptive Requirements of the 2018 Washington State Energy Code (WSEC) and ACCA Manuals J and S. This tool will calculate heating loads only. ACCA procedures for sizing cooling systems should be used to determine cooling loads.

Please complete the green drop-downs and boxes that are applicable to your project. As you make selections in the drop-downs for each section, some values will be calculated for you. If you do not see the selection you need in the drop-down options, please contact the WSU Energy Program at energycode@energy.wsu.edu or (360) 956-2042 for assistance.

Project Information

Lund Residence Fire Restoration and Addition
 8520 SE 82nd ST.
 Mercer Island, WA 98040

Contact Information

Rich Design Group, LLC
 Rich Melchior
 (253) 951-8049

Heating System Type: All Other Systems Heat Pump

To see detailed instructions for each section, place your cursor on the word "Instructions"

Design Temperature

[Instructions](#)

Mercer Island

Design Temperature Difference (ΔT) 45
 $\Delta T = \text{Indoor (70 degrees)} - \text{Outdoor Design Temp}$

Area of Building

Conditioned Floor Area

[Instructions](#)

Conditioned Floor Area (sq ft)

3,915

Average Ceiling Height

[Instructions](#)

Average Ceiling Height (ft)

9.0

Conditioned Volume
 35,235

Glazing and Doors

[Instructions](#)

U-0.30

U-Factor X Area = UA
 0.300 X 610 = 183.09

Skylights

[Instructions](#)

U-Factor X Area = UA
 0.50 X 16 = 8.00

Insulation

Attic

[Instructions](#)

Select R-Value

U-Factor X Area = UA
 No selection X = ---

Single Rafter or Joist Vaulted Ceilings

[Instructions](#)

R-49 Advanced

U-Factor X Area = UA
 0.020 X 737 = 14.74

Above Grade Walls (see Figure 1)

[Instructions](#)

R-21 Intermediate

U-Factor X Area = UA
 0.056 X 2,171 = 121.58

Floors

[Instructions](#)

R-30

U-Factor X Area = UA
 0.029 X 196 = 5.68

Below Grade Walls (see Figure 1)

[Instructions](#)

R-10 Continuous Exterior

U-Factor X Area = UA
 0.064 X 809 = 51.78

Slab Below Grade (see Figure 1)

[Instructions](#)

R-5 Thermal Break at slab edge

F-Factor X Length = UA
 0.570 X 83 = 47.31

Slab on Grade (see Figure 1)

[Instructions](#)

R-10 Perimeter

F-Factor X Length = UA
 0.540 X 196 = 105.57

Location of Ducts

[Instructions](#)

Conditioned Space

Duct Leakage Coefficient
 1.00




Figure 1.

Sum of UA	537.75
Envelope Heat Load	24,199 Btu / Hour
<i>Sum of UA x ΔT</i>	
Air Leakage Heat Load	17,124 Btu / Hour
<i>Volume x 0.6 x ΔT x 0.018</i>	
Building Design Heat Load	41,323 Btu / Hour
<i>Air leakage + envelope heat loss</i>	
Building and Duct Heat Load	41,323 Btu / Hour
<i>Ducts in unconditioned space: sum of building heat loss x 1.10</i>	
<i>Ducts in conditioned space: sum of building heat loss x 1</i>	
Maximum Heat Equipment Output	51,653 Btu / Hour
<i>Building and duct heat loss x 1.40 for forced air furnace</i>	
<i>Building and duct heat loss x 1.25 for heat pump</i>	