



DB589-y
Antenna
installed at top
center, 110'

cable is
secured down
the tower,
follows Ice
bridge into back
of building.



cable is
secured along
ceiling into
control room
where the M400
is mounted to
the wall.

120V Service
needed System
Max draw is 5
amps/600W

**Drawing 2: Location 4 - City of Mercer Island Reservoir
City of Mercer Island Water Meter Data Collector Installation Project
Conditional Use Permit**