

**From:** Jeromy Hicks  
**Sent time:** 06/01/2021 02:43:52 PM  
**To:** Chris Niederman <Chris@niederman.com>  
**Subject:** Gate Permit 2105-227  
**Attachments:** 2105-227-SUB1-PLANS-DENIED.pdf

---

Good Afternoon Chris,

Hope you are doing well!

Thank you for submitting your gate permit.

I have attached a copy of the gate standards and will need a bit more information prior to approval. Simple stuff, but some basics that are listed on pages 3 and 4.

I agree with the width, but will need to know where this is being placed. My assumption is on the property (minus setbacks) and will be constructed to open inwards. Additionally I will need to know the opening mechanism, battery back-up, fail safe open when power is out, UL standards, and the access method you are choosing. If it is 'Click to Enter' then great.. if not I need it noted on the plans were the pedestal or Knox Switch will be located.

Again my assumption is a gate company is installing this for you... all of the information should be pretty easy to obtain from them... just show them my email. I hate to assume.

When you get the info, submit directly back to me. I will upload it for you and get the plans completed.

Let me know if you have any questions.

Jeromy



Jeromy Hicks, Fire Marshal  
City of Mercer Island  
206-275-7966

3030 78<sup>th</sup> Ave SE  
Mercer Island, WA 98040

**\*\* PLEASE NOTE MY EMAIL ADDRESS CHANGE\*\***     [Jeromy.hicks@mercerisland.gov](mailto:Jeromy.hicks@mercerisland.gov)