

Work Order: 22883 Customer #: 10402



Invoice Date Due Date Terms 33008 02/08/23 03/10/23 Net 30

Bill To: 77 Central Apartments 2630 77th Ave SE Mercer Island, WA 98040 Service Location: 77 Central Apartments 2630 77th Ave SE Mercer Island, WA 98040

Requested By: Miranda Rainbolt

Scope Detail: HP-07-RM311 Fan Coil Replacement, 77centralmgr@cushwake.com: Terry.Graham@cushwake.com:

Work Description: HP-07-RM311 Fan Coil Replacement

Auburn Mechanical provided labor and materials needed to remove the line set from the fan coil. Removed coil from fan coil, installed new fan coil, and LEV hooked up line set and pressure tested. After passing pressure test, evacuated and released refrigerant isolation valves. Proper operation was verified and the job is complete per scope. Thank you for choosing Auburn Mechanical.

Price Method: Flat Price

Description		Price Total
Per Approved Quote		
Flat Price		2,846.50
		0.040.50
	Subtotal	2,846.50
	Тах	287.50
	Total	3,134.00